

# General Environmental Incident Summary

**Incident:** 3241      **Date/Time Notice:** 2/20/2014      1230      **DEM Incident No:**

**Responsible Party:** Xcel Energy

**Date Incident:** 2/20/2014      **Time Incident:** 1230      **Duration:**

**County:** Cass      **Twp:** 139      **Rng:** 49      **Sec:** 10      **Qtr:** NW NE

**Lat:** 46.87540      **Long:** -96.84984      **Method:** Interpolation from map

**Location Description:** 4102 Main Avenue, Fargo, ND (Large Substation on corner)

**Submitted By:** Rob Volk

**Affiliation:** Xcel Energy

**Address:** 2302 Great Northern Drive

**City:** Fargo

**State:** ND

**Zip:** 58102

**Received By:** Emily Tintes Schiwal

NDDH - Waste Mana

**Contact Person:** Rob Volk

2302 Great Northern Drive

Fargo, ND 58102

**Distance Nearest Occupied Building:** 200 Feet

**Type of Incident:** Transformer Leak

**Description of Released Contaminant:** Non-PCB Mineral Oil

**Volume Spilled:** 5.00 gallons

**Ag Related:** No

**EPA Extremely Hazardous Substance:** No

**Reported to NRC:** No

**Cause of Incident:**

unknown

**Risk Evaluation:**

None

**# of Fatalities:** 0

**# of Injuries:** 0

**Affected Medium:** 03 - soil

**Potential Environmental Impacts:**

None likely in this event.

**Action Taken or Planned:**

Xcel staff used absorbents to clean the spill from the concrete pad and surrounding soils.

**Wastes Disposal Location:** All wastes will be sent to Xcel's Minneapolis hazardous waste facility and properly disposed of from there.

**Agencies Involved:** Fargo Cass Public Health

## ***Updates***

---

***Date:*** 2/20/2014    ***Status:*** Reviewed - Assigned to NDDoH Division

***Author:*** Stockdill, Scott

### ***Updated Volume:***

### ***Notes:***

According to the incident summary, this spill involved non-PCB mineral oil. Forwarded to Emily Schiwal in Division of Waste Management.